Selection Software Update — Rating Notice

AHRI Liquid to Liquid Heat Exchangers (LLHE) Certification Program · Issue date: 5 November 2026

ARES PHE has released an update to its AHRI-approved selection software, **ARES PHE AHRI V0326.2**. This update revises the certified heat transfer ratings of the model groups below.

Updated ratings

Basic Model Group	Models	Heat transfer rating
BMG 60	AH6L, AH6M, AH6S, AH6XL	94.6% of the previously published value
BMG 120	AH12L, AH12M, AH12S	89.7% of the previously published value*

Pressure drop ratings are unchanged. All other ARES models are unchanged.

**For the AH12 models, the update also limits selections to the valid operating range of the plate, at an LMTD of 1.0 °C and above.*

What to do

- Selections for the models above generated with an earlier software version should be re-run with the current version before use.
- ARES PHE USA will re-issue any such selection on request.

Verification and contact

Current certified ratings are listed in the AHRI Directory at www.ahridirectory.org.